

September 9, 2026

DeMotte Christian Schools has taken the following steps to address the notes from the mold inspection from August 25th.

- 1) **410 IAC 33-4-2 (b): states “carbon dioxide concentrations in the breathing zone shall never exceed 700 ppm over the outdoor concentration.”** DeMotte Christian Schools is working to raise money to address the carbon dioxide levels in the classrooms, as several of the classrooms were over the suggested limit. In addition, DMCS is examining its current HVAC system to address problems within the currently installed system.
- 2) **410 IAC 33-4-6 (d): states “when mold or mold-contaminated material is discovered, corrective action shall be taken within forty-eight (48) hours. Mold is not to be growing in the school.”** Ceiling tiles are examined and replaced by janitorial staff when they become discolored.
- 3) **410 IAC 33-4-6 (c): states “when a water leak or intrusion is discovered, corrective action shall be taken within forty-eight (48) hours.”** Leaks are addressed by janitorial staff in a timely fashion. DMCS is also using fundraisers to have the roof repaired again.
- 4) **410 IAC 33 also requires schools to have written policies for Vehicle Idling, Animals in Classrooms, and Chemical Management.** These policies have been placed in the education procedure manual after being adapted from the best practices manual.
- 5) **410 IAC 33 requires schools to designate an individual as their Indoor Air Coordinator and states “The IAQ Coordinator’s contact information shall also be published: 1) on the school website and 2) in the school handbook.”** Principals of each building for DeMotte Christian Schools are designated as the IAQ Coordinator. Contact information can be found on the school website and in the school handbook.
- 6) **410 IAC 33-5 a) states “Schools shall establish and maintain a written procedure for routine maintenance of HVAC systems.”** A written procedure following our standard protocols has been developed and placed in the building and grounds policy book.

Thank you,

Jeremy Boer  
Principal  
DMCGS